

COMPACT CIP CONTROL SYSTEMS



CSI

INSTALLATION / OPERATION / MAINTENANCE

TABLE OF CONTENTS

Contents	2
The meaning of DANGER, WARNING, and CAUTION in these instructions.	3
About This Manual.	4
Application	4
Technical Data	4
At A Glance (Equipment Overview).	5
Built-in Safety	6
Disclaimer of Liability.	7
Air Connections	7
Control Panel	7
System Start	8
Wash Settings.	10
Tank Settings	13
System Options	14
Wash Types and Wash Commands.	15
Starting your first Wash Cycle	16
Trend Screen.	17
History Screen	17
Alarm Screen	18
Alarm Statuses Explained.	19
Pump VFD Fault	19
High Temp Alarm	19
High Cond Alarm	19
Low Flow Alarm	19
Tank High Level Alarm	19
Tank Low Level Alarm	19
Transmitter Errors - Return Temp, Supply Temp, Conductivity, Flow, Level	19
Interlocks Explained	20
Interlock - CIP Supply Pump.	20
Interlock – Electric Heater (If Equipped).	20
Interlock – Chemical Pumps (If Equipped).	21
E-Stop Active.	21
Maintenance Checklist	22
Replacing Components.	23
Replacing Poly Tubing.	23
Replacing Pressure Regulator Filter Element	24
Replacing the Solenoid Valve	25
Troubleshooting	26
Warranty.	27-28



IMPORTANT SAFETY INFORMATION

The Compact CIP Manual includes essential information for installing, operating, and maintaining equipment properly and in a safe manner. Failure to do so could result in personal injury and/or equipment damage.

DO NOT attempt to remove and/or modify Compact CIP products or programming. Doing so can create unsafe conditions for operator(s) and surrounding persons. Changes to Compact CIP products or programming void all warranties.

DO NOT place any Compact CIP product in an application where general product service ratings are exceeded. Doing so puts operator(s) and surrounding persons at risk of personal injury and may result in equipment damage.

THE MEANING OF DANGER, WARNING, AND CAUTION IN THESE INSTRUCTIONS

Danger: Indicates an imminently hazardous situation which, if not avoided, has a high likelihood of resulting in death or serious injury. The word Danger indicates the most extreme cases of risk that warrant immediate action.

Warning: Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury. The word Warning is used for moderately at-risk cases that warrant immediate action.

Caution: Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury. "Caution" may also indicate an unsafe operating or maintenance practice.

If at any point during operation, a Danger, Warning, or Caution indication is present, the operator should immediately take steps to resolve the problem and notify a supervisor.

Do not remove warning labels on any Compact CIP product. Immediate replacement of missing labels is important to the safety of all users.



INTRODUCTION

Thank you for purchasing a Compact CIP Product!

This manual contains operation instructions for the Compact CIP Control System.

ABOUT THIS MANUAL

This manual covers the complete line of Compact CIP systems. All Compact CIP systems are available with optional equipment that can provide additional functionality.

Please contact **CSI at 800.721.2394 or 417.831.1411** for assistance.

APPLICATION

CSI's Compact CIP regulates the operation of your Clean-in-Place system. Compact CIP takes the guesswork out of configuring and selecting the start, stop, flow, temperature, and chemical concentration required for a successful clean-in-place cycle. If used properly, your Compact CIP system can be a source of savings and a vital step in ensuring product quality through rapid and effective cleaning.

TECHNICAL DATA

- Compressed air pressure: 90–100 psig (requires at least 90, no more than 100)
- Air inlet size: 1/2" FNPT
- Maximum product pressure: 145 psig
- Product Temperature range: 0°F–180°F
- Electrical Requirement: AC 480V, 60Hz +/- 6%
- Amperage requirement based on system configuration: 20Amps without electric heat, 57 Amps with electric heater option.



AT A GLANCE

- 1 Touchscreen
- 2 Emergency Stop (E-Stop)
- 3 Return Temperature & Conductivity Transmitter
- 4 Power Disconnect Switch
- 5 Supply Temperature Transmitter
- 6 Electric Heater (optional)
- 7 Pressure Gauge
- 8 Flow Transmitter
- 9 Tank
- 10 Control Panel
- 11 Chemical Reservoirs
- 12 Tank Level Transmitter



SAFETY



BUILT-IN SAFETY

The CSI Compact CIP control package includes built-in safety features including air lockout and emergency stop capabilities. The control units can also incorporate system timeouts for added operator safety.

AIR LOCKOUT CAPABILITY

1 The photo on the left shows the air control in the Supply (SUP) position. To prevent accidental operation, turn the air control to the OFF position and lock it with a padlock (OSHA lockout/tagout standard for control of hazardous energy).



E-STOP CAPABILITY

Activate E-Stop to turn off all operations.

To release the E-Stop, twist clockwise until it pops up.



INSTALLATION

The Compact CIP control cabinet arrives mounted to the skid and prewired to instruments installed on the skid. Typical installation requires a dedicated 480V 3-Phase with Branch Circuit Protection with amperage requirement based on system configuration: 20 Amps without electric heat, 57 Amps with electric heater option. Electrical schematics provided with the control panel indicate the location, voltage and amperage requirement for the panel. The Compact CIP system is designed to work as a standalone system and does not require integration with the plant's infrastructure.



WARNING

To avoid electrocution, ALL electrical work should be done by a registered electrician, following industrial safety standards and local codes. All power must be OFF and safely locked out during installation.

DISCLAIMER OF LIABILITY

CSI does not assume responsibility and expressly disclaims liability for loss, damage, or expenses that arise in any way from the installation, operation, use, or maintenance performed in accordance with this manual. CSI assumes no responsibility for any infringement of patents or other rights of third parties that may result from use of the module. No license is granted by implication or otherwise under any patent or patent rights.

CSI reserves the right to make changes to the product, specifications, or this manual without prior notice

AIR CONNECTIONS

Note: CSI recommends that the control cabinet be supplied with clean instrument air at the minimum pressure of 90 psig.

AIR INPUT TO CABINET

- 1 Air connection 1/2" NPT Female



CSI

CONTACT CSI FOR MORE INFORMATION | CSIDESIGNS.COM | SALES@CSIDESIGNS.COM | +1.417.831.1411



OPERATION

CONTROL PANEL

Use the touchscreen control panel to select wash parameters and cleaning cycle. Operators should take a moment to familiarize themselves with the items in bold below.


SYSTEM START

1. Verify all Swing, Hose, and Piping Connections are secure.
2. Verify the **Air Relief Valve** is in the **On** position.
3. Verify the **E-Stop** is not activated.
4. To change wash parameters, press the **Config** button. On the user login screen—
 - a. Input your username and password.
 - b. Default login to change configuration parameters:
User: engineer
Pass: engineer
 - c. Adjust wash settings (e.g., Temperature, Flow, Chemical Concentration)
 - d. Make the desired configuration changes and press the Logoff button.
5. To start the system, ensure it is fully connected in a safe manner and press the **Commands** button. The system presents the available washes.
 - a. Select the desired wash type on the left
 - b. Press the **Start** button on the right.
 - c. Press the **Abort** button to stop and cancel the current wash if needed during the wash.
 - d. Press the **Hold** button to pause the current wash sequence and keep its current position and time remaining. Press the **Restart** button to resume operation.
6. When the system is started, it automatically opens the water fill valve and maintains tank level according to Tank settings located on the **Config** screen.
7. The system continues to run in Automatic mode until the Operator stops the system by pressing the **Abort** button, **Hold** button, **E-Stop** button, or the system goes into an Alarm state.
 - a. If the system goes into Alarm, the issue that caused the alarm must be resolved before continued operation.
 - b. Transmitter errors and tank low level limit alarms are indicated on the screen by a yellow rectangle warning symbol and will auto-acknowledge themselves once the problem has been resolved.

	Displays when a piece of equipment is in an alarm state
	Displays when there is a transmitter error or tank low level limit alarm





OPERATOR INTERFACE SCREENS: MAIN SCREEN



The main screen displays system status.

- 1 The main navigation bar is located at the top of every screen for easy navigation.
- 2 System status area includes the following possibilities:
 - **Current Wash Phase** – System Idle, Pre-Rinse Running, Caustic Running, Rinse Running, Acid Running, System Draining, Final Rinse Running, Sanitizer Running.
 - **Current Wash Conditions** – Waiting Cond. SP, Waiting Temp SP, Waiting Temp & Cond. SP, Wash Conditions Met.
 - **Time Remaining** – The time remaining, in seconds, of the current wash phase. If the timer is not counting down while the system is running, then the system is waiting for a wash condition such as Temperature or Conductivity to be met. (See Wash Settings on page 11.)
- 3 If the system is equipped with an electric heater, its icon turns red when power is supplied to the heater, and displays “Heater On” text above it.
- 4 Equipment indicators change color to green when they are open or running. When the system is sitting idle and there are no active alarms, operators are allowed a small amount of manual control of the system as long as built-in interlock criteria are met. Touch the equipment indicator icon you would like to open or turn on and it will comply if the interlock permissions are met. Press again to close or shutoff the valve. Refer to our Alarms/Interlocks section for more information.
- 5 The system auto-maintains its tank level according to the tank settings configured on the Config screen.
 - The water supply to the skid must be capable of filling at the same or greater rate as the CIP supply pump for effective rinsing. For example, the standard pump is rated for 50gpm at 50 psi, so the supply water to the skids should be at least 50gpm to maintain level.

	Green indicates equipment is open or running
	Red indicates equipment is closed or stopped



OPERATOR INTERFACE SCREENS: CONFIG SCREEN

	1	2	3	4	5	6	7		
Wash Settings									
	Pre-Rinse	Caustic	Rinse	Acid	Drain	Final Rinse	Sanitizer		
Time SP	5	15	15	15	15	15	15	(sec)	High Limit
Temp SP	N/A	85.0	N/A	50.0	N/A	N/A	N/A	(F)	Stop Fill
Cond SP	2.0	0.0	2.0	0.0	N/A	2.0	2.0	(mS)	Start Fill
Flow SP	20.0	(above)	(below)	(above)	(below)	(below)	(below)		Low Limit
Chem SP	10.0	2.0	2.0	60	60				
	Cycle Time	Pulse Caustic	Pulse Acid	Caustic Pump Runtime	Acid Pump Runtime				
Tank Settings									
									Level %
									100.0
									40.0
									30.0
									4.0
System Options									
Has Plant Integration			Has Caustic Pump		Caustic Dosing by Time			Main Terminal	
Has Electric Heater			Has Acid Pump		Acid Dosing by Time			 CSI 417.831.1411 csidesigns.com	

TC-Compact-CIP-Rev11 6/11/2020

The configuration screen displays the overall system settings that can be adjusted to the desired CIP wash parameters by allowed users.

WASH SETTINGS

Wash settings include Time, Temperature (Temp), Conductivity (Cond), Flow, and Chemical (Chem) Setpoints (SP) for each wash phase — from Pre-rinse to Sanitizer. The Compact CIP will not advance to the next step in the wash cycle until the system is either above or below the setpoint.

- 1 **Pre-rinse** — waits until the system is at or above Flow SP and below Cond SP.
- 2 **Caustic** — waits until the system is at or above Cond SP, Temp SP, and Flow SP.
- 3 **Rinse** — waits until the system is at or above Flow SP and below Cond SP.
- 4 **Acid** — waits until the system is at or above Temp SP, Cond SP, and Flow SP.
- 5 **Drain** — waits until the system is tank is below low limit SP.
- 6 **Final Rinse** — waits until the system is at or above Flow SP and below Cond SP.
- 7 **Sanitizer** — waits until the system is at or above Flow SP and below Cond SP.

For example, in the screenshot shown above, the Pre-rinse phase will not advance to the Caustic phase until the Flow SP is at or above 20.0 and the Cond SP is below 2.0. The Temp SP has a value of N/A which indicates that there is neither a minimum nor maximum requirement for the Pre-rinse Temperature (Temp SP) and therefore will not delay advancement to the next phase.

OPERATOR INTERFACE SCREENS: CONFIG SCREEN

Note: When a Flow SP of 50.0 is entered on the Config screen, the pump flow control will actually try to achieve and maintain 55 gpm to ensure that the flow is always above the minimum target (or SP).

Note: Temperature is controlled in a similar way. When a Temp SP of 160 is entered on the Config screen, the heat exchanger will actually try to achieve and maintain 165°F to ensure that the temperature is always above the minimum target (or SP).

Note: Most sanitizers used in the sanitary industry don't have a good conductivity profile, so typical operation of this system is to dose the desired amount of sanitizer in the tank at the beginning of a Sanitizer wash phase.



OPERATOR INTERFACE SCREENS: CONFIG SCREEN

Wash Settings								Tank Settings		
	Pre-Rinse	Caustic	Rinse	Acid	Drain	Final Rinse	Sanitizer		Level %	
1 Time SP	5	15	15	15	15	15	15	(sec)	High Limit	100.0
2 Temp SP	N/A	85.0	N/A	50.0	N/A	N/A	N/A	(F)	Stop Fill	40.0
3 Cond SP	2.0	0.0	2.0	0.0	N/A	2.0	2.0	(mS)	Start Fill	30.0
4 Flow SP	20.0	(above)	(below)	(above)	(below)	(below)	(below)		Low Limit	4.0
5 Chem SP	10.0	2.0	2.0	60	60					

System Options		
6 Has Plant Integration	7 Has Caustic Pump	8 Caustic Dosing by Time
9 Has Electric Heater	10 Has Acid Pump	Acid Dosing by Time

- 1 **Time SP** – The desired hold time the wash conditions need to be met before the system can move on to the next wash phase.
- 2 **Temp SP** – The Caustic and Acid wash phases require a temperature setpoint be reached before the timer can count down.
- 3 **Cond SP** – The desired SP of the chemical conductivity level for the desired concentration. Caustic and Acid Phases must be over their configured setpoints; Pre-Rinse, Rinse, Final-Rinse and Sanitizer phases must be below their configured setpoints.
- 4 **Flow SP** – The desired flow rate of the CIP system for all wash phases.
- 5 **Chem SP** – If the system is configured for automated chemical dosing, the following settings appear. (Note: This system is designed to pulse in small amounts of chemicals at a time and bring the whole CIP loop up to concentration rather than initially dosing a large amount of chemicals and potentially overshooting concentration targets.)
- 6 **Cycle Time** – How often the chemical pump doses chemical during a Caustic or Acid wash phase. (Default is 10 seconds.)
- 7 **Pulse Caustic** – How long the chemical pump stays on when it doses chemicals during a Caustic wash phase. (Default is 2 seconds.)
- 8 **Pulse Acid** – How long the chemical pump stays on when it doses chemicals during a Acid wash phase. (Default is 2 seconds.)
- 9 **Caustic Pump Runtime** – A time setting that will allow the caustic pump to run for a set amount of time and shut off, rather than looking to achieve a set conductivity level.
- 10 **Acid Pump Runtime** – A time setting that will allow the acid pump to run for a set amount of time and shut off, rather than looking to achieve a set conductivity level.



OPERATOR INTERFACE SCREENS: CONFIG SCREEN

The screenshot shows the 'Alarms' tab in the Operator Interface. The 'Tank Settings' section is highlighted with four callouts:

- 1. High Limit: 100.0%
- 2. Stop Fill: 40.0%
- 3. Start Fill: 30.0%
- 4. Low Limit: 4.0%

Other settings visible include:

Wash Settings								Tank Settings		
	Pre-Rinse	Caustic	Rinse	Acid	Drain	Final Rinse	Sanitizer		Level %	
Time SP	5	15	15	15	15	15	15	(sec)	High Limit	100.0
Temp SP	N/A	85.0	N/A	50.0	N/A	N/A	N/A	(F)	Stop Fill	40.0
Cond SP	2.0	0.0	2.0	0.0	N/A	2.0	2.0	(mS)	Start Fill	30.0
Flow SP	20.0	(above)	(below)	(above)	(below)	(below)	(below)		Low Limit	4.0
	Cycle Time	Pulse Caustic	Pulse Acid	Caustic Pump Runtime	Acid Pump Runtime					
Chem SP	10.0	2.0	2.0	60	60					

System Options:

- Has Plant Integration
- Has Caustic Pump
- Caustic Dosing by Time
- Has Electric Heater
- Has Acid Pump
- Acid Dosing by Time

Main Terminal

CSI 417.831.1411 csidesigns.com

TC-Compact-CIP-Rev11 6/11/2020

TANK SETTINGS

Configures how the Tank Level operates when the system is Active.

- 1 **High Limit** – Tank High Level Fill Alarm setpoint. System Alarms and aborts current washes in the event the tank gets overfilled.
- 2 **Stop Fill** – When the system is refilling with Fresh Water it stops filling at this setpoint to prevent from overfilling the tank (default is 80%).
- 3 **Start Fill** – When the system is running and the tank volume falls below this amount, the water inlet valve opens and starts refilling the system until it reaches the configured Stop Fill amount or the current wash phase completes.
- 4 **Low Limit** – Tank Low Level Limit Alarm setpoint. The system outputs a warning if the tank volume falls below this amount and the pump is prevented from running until the level in the tank is returned to a normal amount. This is by design to prevent the pump seals from running dry.

OPERATOR INTERFACE SCREENS: CONFIG SCREEN

Wash Settings								Tank Settings		
	Pre-Rinse	Caustic	Rinse	Acid	Drain	Final Rinse	Sanitizer		Level %	
Time SP	5	5	15	15	15	15	15 (sec)	High Limit	100.0	
Temp SP	N/A	85.0	N/A	50.0	N/A	N/A	N/A (F)	Stop Fill	40.0	
Cond SP	2.0	0.0	2.0	0.0	N/A	2.0	2.0 (mS)	Start Fill	30.0	
Flow SP	20.0	(above)	(below)	(above)	(below)	(below)	(below)	Low Limit	4.0	
Cycle Time		Pulse Caustic	Pulse Acid	Caustic Pump Runtime	Acid Pump Runtime					
Chem SP	10.0	2.0	2.0	60	60					

System Options		
Has Plant Integration	Has Caustic Pump	Caustic Dosing by Time
Has Electric Heater	Has Acid Pump	Acid Dosing by Time

TC-Compact-CIP-Rev11 6/11/2020

CSI 417.831.1411 csidesigns.com

SYSTEM OPTIONS

These are set at the factory with the options purchased with the system.

- 1 When **Has Plant Integration** is configured, the button will turn green (not blue) and will enable communication between skid and plant via ethernet. When **Standalone System** is configured, the button will turn blue (not green) and does not allow communication via ethernet.
- 2 **Has Electric Heater** – Allows the system to heat and maintain temperature during the Caustic and Acid phases of the wash cycle.
- 3 **Has Caustic Pump** – Allows automated chemical dosing of Caustic during the Caustic wash phase.
- 4 **Has Acid Pump** – Allows automated chemical dosing of the Acid during the Acid wash phase.
- 5 When **Caustic Dosing by Time** is configured, the button will turn green (not blue) and the “Caustic Pump Runtime” numeric entry box will appear. When **Caustic Dosing by Conductivity** is configured, the button will turn blue (not green) and the “Caustic Pump Runtime” numeric entry box will disappear.
- 6 When **Acid Dosing by Time** is configured, the button will turn green (not blue) and the “Acid Pump Runtime” numeric entry box will appear. When **Acid Dosing by Conductivity** is configured, the button will turn blue (not green) and the “Acid Pump Runtime” numeric entry box will disappear.



OPERATOR INTERFACE SCREENS: COMMANDS SCREEN



WASH TYPES


- 1 Caustic Wash Phases:** Pre-Rinse, Caustic, Drain, Final-Rinse
- 2 Caustic Sanitizer Wash Phases:** Pre-Rinse, Caustic, Drain, Final-Rinse, Sanitizer
- 3 Caustic Acid Wash Phases:** Pre-Rinse, Caustic, Drain, Rinse, Acid, Drain, Final-Rinse
- 4 Caustic Acid Sanitizer Wash Phases:** Pre-Rinse, Caustic, Drain, Rinse, Acid, Drain, Final-Rinse, Sanitizer
- 5 Sanitizer Wash Phases:** Sanitizer

WASH COMMANDS

- 6 Start:** Starts the automated sequence of the selected wash type.
- 7 Hold:** When the system is running, the operator can put the system in a Hold state to stop the active wash but maintain the current timers so the system can restart from where it was paused without starting the sequence over.
- 8 Restart:** When the system is in the Held position the operator can resume the current wash from where they left off.
- 9 Abort:** Shuts down the system, canceling the active wash and putting the system into an Idle state. This may also happen if a High Limit Alarm goes active or an operator presses the E-Stop button on the control panel.



STARTING




STARTING YOUR FIRST WASH CYCLE

- 1 Select the desired wash type. The selected wash is now displayed at the top. Prior to starting the wash, the operator can change the desired wash type by deselecting the previous option before selecting the new option.
- 2 Press the Start command. The Start button turns green.
- 3 Once the system is running, the Hold and Abort buttons are available if needed during the wash cycle, and the operator can return to the Main to monitor skid operation.




TREND SCREEN




1 The Trend screen logs the actual process values of Supply Flow (Flow), Supply Temperature (S-Temp), Return Temperature (R-Temp), and Return Conductivity (Cond). These data points are sampled every second and plotted on the same graph for wash monitoring. This graph will display up to 8 minutes (480 seconds or t-480) of data.

2 The History screen logs the actual process values of Supply Flow, Supply Temperature, Return Temperature, and Return Conductivity exactly as the Trend screen does. The difference is the data points are sampled every eight seconds allowing for monitoring a longer time frame such as a complete wash cycle. This graph will display up to 1 hour (3600 seconds or t-3600) of data. Both the History and Trend screens are limited to 500 data points.


HISTORY SCREEN



ALARM SCREEN



- 1 When the system has an active alarm, the Alarm button flashes red on every screen indicating a system problem. The skid aborts current washes and returns itself to an idle state. Pressing the Alarm button on the main navigation screen activates the Alarm screen. On the Main screen a small red bell also displays next to the piece of equipment currently in an alarm state.
- 2 The alarm screen displays the system alarms built into the Compact CIP system. Any active alarms turn Red with an illuminated border. Transmitter errors and tank low level alarms auto-acknowledge once the problem has been resolved; however, there are an additional four alarms that require an operator to acknowledge the alarm before the system can operate again. If the alarms do not clear, then the issue that caused the alarm is still in effect.



ALARM SCREEN

ALARM STATUSES EXPLAINED

PUMP VFD FAULT

The VFD in the control panel has a fault. This can be loss in Ethernet communication such as when a new program is downloaded. It could also be a true VFD fault such as motor overcurrent.

HIGH TEMP ALARM

The system is set to a max temperature of 180°F. In the event temperature exceeds 180°F, the High Temp Alarm activates and current washes abort.

HIGH COND ALARM

The system is set to a max chemical conductivity of 100mS/cm. In the event chemical conductivity exceeds 100mS/cm, the High Cond Alarm activates and current washes abort.

TANK HIGH LEVEL ALARM



The system has a configurable Tank High Level limit which is set to 100% as default. Tank level of 100% is set at the factory to be about 2-3" below the overflow in the tank. In the event the tank level reaches higher than the configured setpoint the High Tank Level Alarm activates and any current washes abort.

TANK LOW LEVEL ALARM


The system has a configurable Tank Low Level limit which is set to 10% as default. In the event the tank level drops below the configured setpoint, the Supply Pump interlocks to prevent it from running, and the Low Level Warning Alarm activates. The current wash does not abort with this alarm but holds the system and waits for the tank level to return in order to complete the wash. (Note* The water supply to the skid must be capable at filling the same or greater rate as the CIP supply pump for effective rinsing. For example, the standard pump is rated for 50gpm at 50 psi so the supply water to the skids should be at least 50gpm to maintain level.)

TRANSMITTER ERRORS - RETURN TEMP, SUPPLY TEMP, CONDUCTIVITY, FLOW, LEVEL

If the analog signal goes below or above the normal operating range of 4-20mA the system assumes there is a problem with the transmitter and the Transmitter alarm activates and current washes abort. Once the transmitter is fixed and receiving the 4-20mA analog range the alarm automatically clears itself.

	Displays when a piece of equipment is in an alarm state
	Displays when there is a transmitter error or tank low level limit alarm

ALARM STATUS: INTERLOCKS



Displays when there is an interlock

INTERLOCKS EXPLAINED

1 When an interlock is active on a device in the system a small stop sign with a “P” displays on the screen next to the piece of equipment that has an active interlock. The P stands for permission. Some of the devices have more than one interlock criteria and that are explained in more detail below.

INTERLOCK – CIP SUPPLY PUMP

The CIP supply pump has the following interlock criteria that must be met prior to the pump operating.

1. The system is not in an E-Stop condition.
2. The pump is not in Alarm.
3. The tank discharge valve is commanded to be open.
4. The tank level has more liquid than the minimum configured tank Low Limit set under Tank settings on the Configuration screen. (Default is 10% level).

INTERLOCK – ELECTRIC HEATER (IF EQUIPPED)

The electric heater has the following interlock criteria that must be met prior to the heater being allowed to operate.

1. The system is not in an E-Stop condition.
2. The heater is not in Alarm.
3. The CIP system is in a Running State status.
4. The CIP supply flow is greater than 10gpm.
5. The CIP supply temperature is less than 190°F.

ALARM STATUS: INTERLOCKS

INTERLOCK – CHEMICAL PUMPS (IF EQUIPPED)

The chemical pumps have the following interlock criteria that need to be met prior to them being allowed to operate.

1. The system is not in an E-Stop condition.
2. The heater is not in Alarm.
3. The CIP system is in a Running State status.
4. The CIP supply flow is greater than 10gpm.
5. The CIP Return chemical conductivity is less than 100mS/cm.

E-STOP

E-STOP ACTIVE

The system is powered on and the E-Stop button has been activated. The system shuts down and inhibits all devices from operating until the E-Stop button is released by the operator turning the button clockwise. An E-Stop active status appears on the screen.



MAINTENANCE



WARNING

Warning: Employees should not perform maintenance on the CIP control system before ensuring a safe work environment.

To ensure a safe work environment, it is recommended, but not limited to, verifying the following precautions are met:

- Power to the control panel should be OFF and Locked Out
- Remove or Lock Out the inbound air supply from the pressure regulator

General cleanliness extends the life of your control panels and its components. The area should be kept free of spills and loose debris. Under NO circumstance should the panel be sprayed down or cleaned with any wet fluids. Doing so could damage the electrical and/or pneumatic equipment.

If hardware issues exist, cease all use of the CIP Control Panel until all issues are resolved.

MAINTENANCE CHECKLIST

- Check air lines for cracks and leaks.
- Check pressure drop across air filter; if pressure drop exceeds maximum allowable, the filter must be cleaned or replaced.
- Check for loose connections or connectivity with solenoid valves

Note: The pressure drop should not exceed 14psig; if the pressure drop exceeds the maximum allowable the filter needs to be cleaned or replaced.

Note: A solenoid valve does not typically give advance warning before failing.



CSI

CONTACT CSI FOR MORE INFORMATION | CSIDESIGNS.COM | SALES@CSIDESIGNS.COM | +1.417.831.1411

MAINTENANCE

REPLACING COMPONENTS

The instructions below describe how to replace components used in the manufacturing of a Compact CIP control system.

REPLACING POLY TUBING

1. Ensure that the Control Panel is powered down.
2. Disconnect the inbound airline at the pressure regulator.
3. Press in the outer ring of the pneumatic fitting, and then gently pull the cracked or leaking airline from the fitting.
4. Repeat the same procedure for the other end of the airline.
5. Use the cracked or leaking airline as a guide for the length of the new airline.
6. Trim the new section of airline to the appropriate length.
7. Install airline by pressing each end into pneumatic fittings.

Note: Make certain the outer rings on the pneumatic fittings extend after the new line is pressed in. If fittings are not fully extended outward, the hose could be blown out from its seated position when subjected to sufficient pressure.




MAINTENANCE

REPLACING PRESSURE REGULATOR FILTER ELEMENT

SMC, the manufacturer of the supplied filter regulator, recommends the filter element be changed every two years or when the pressure drop across the element exceeds 14 psig.

1. Locate the spring-loaded release on the front of the pressure regulator.
Note: Before proceeding to the next step, ensure the air supply is shut off and disconnected before removing the filter casing.
2. Press the release down and hold.
3. Turn the portion of the pressure regulator body below the spring-loaded release.
 - This may be more easily accomplished by holding the release with the thumb of the hand with which you intend to turn the body.
 - The pressure regulator body should only need to turn approximately half of a revolution before gently pulling it free.

Note: If you only turn the body a quarter of a turn, the release may try to extend back into place.



4. Once the body of the regulator is removed, the element can be easily removed and replaced.
5. Put the body back on and turn it back into position directly opposite of how you removed it. This should seat the body exactly where it began.

MAINTENANCE

REPLACING THE SOLENOID VALVE

Although solenoid valves used by Compact CIP are rated for one million cycles, there are no performance guarantees for these items. While we do not guarantee a particular number of cycles, we are confident the valves are free from manufacturer defects.

1. Remove retaining screws from the existing solenoid valve.
Note: Keep them until you are certain new screws have been provided.
2. Gently remove the solenoid valve from the mounting pad.
3. Take note of how the solenoid valve is oriented.
4. Take note of all O-rings, as there may be small O-rings on sealing surfaces.
5. In some cases, the top or bottom of the solenoid valve may need to come out first.
6. Verify the O-rings are properly placed on the new solenoid valve.
Note: It may be necessary to insert or seat one end of the solenoid valve before the other end seats properly.
Note: It should never be necessary to force the new solenoid valve into place.
7. Install the retaining screws that you removed in step (a). If new retaining screws were provided, use them and discard the screws from step (a).



TROUBLE- SHOOTING

Q. WHAT SHOULD I DO IF THE AUTOMATED VALVES ARE NOT OPERATING?

Ensure that the OSHA Air Dump valve is in the ON position and the supply pressure is over 90psi.

Q. WHAT SHOULD I DO IF I CAN'T RUN THE CIP PUMP?

Check the CIP Supply pump interlocks and ensure all the criteria to operate have been met.

Ensure the VFD is not faulted and the E-Stop is not inhibiting its operation.

The supply pump can sometimes airlock when the system first starts and the process lines are dry. Command the current wash to hold and wait for the pump to stop; then press the resume command. Many times, Hold/Resume clears the air lock.

Ensure the pump is rotating with the correct rotation and with the system safely locked out, then ensure the pump impeller spins freely without interference or resistance.

Q. WHAT SHOULD I DO IF I CAN'T RUN THE HEATER?

Verify that the supply flow is greater than 10 GPM, which is a safety feature that ensures enough water flow for the heater to run.

Ensure the control system temperature setpoint is set on the desired temperature and that the return temp is lower than that value.

Please Note: For questions or concerns regarding your CIP Control System, please contact CSI at **800.721.2394** or **417.831.1411**.



WARRANTY

- A. **GENERAL PROVISIONS:** Central States Industrial Equipment & Service Inc. (the “Company”) warrants exclusively to the original purchaser (the “Customer”) that equipment or parts thereof manufactured and sold by the Company will be free from defects in material and workmanship only, under normal use and service, for a period of one (1) year from the original shipment date. The Company shall not be liable for any loss of revenue or profit, loss by reason of plant shutdown, non-operation or increased cost of operation, loss of products or materials, or other special or consequential loss or damages resulting from any such warranted defects. This warranty will not apply to any equipment or parts which has been subjected to accident, alteration, abuse, or misuse. This warranty is in lieu of all other warranties. All other warranties, both express or implied (including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose) warranties are hereby excluded and waived. The Company’s only obligation and liability shall be to fulfill the warranty specifically stated herein. The Company will neither assume nor authorize any other person to assume for it any other obligation or liability in connection with the equipment or parts. In the event of a claim under this warranty, the Company’s sole and exclusive liability for any warranted equipment or parts shall be, at the Company’s option, limited to the following (a) the purchase price of the equipment or parts that are defective, (b) replacement of the defective equipment or parts or (c) repair of the defective equipment or parts.
- B. **RETURN OF PARTS OR EQUIPMENT TO COMPANY PLANT:** In the event the Company elects to inspect the alleged defective equipment or parts for possible repair, Company will notify Customer in writing, and the equipment or parts must be returned with transportation cost prepaid by the Customer. In the event the Company’s inspection confirms defective equipment or parts covered by this warranty, the Company shall have the option to select any of the remedies described in Section A above. No transportation for returned or replaced items will be paid by the Company unless written approval for transportation charges is given by the Company.
- C. **COMPONENTS NOT MANUFACTURED BY THE COMPANY:** Components not manufactured by the Company, but furnished as part of its equipment (for example: valves, controls, gauges, electrical switches or instruments, etc.) will be warranted by the Company only to the extent of the component manufacturer’s warranty.



WARRANTY

D. REPAIR OF EQUIPMENT INSTALLED IN THE CONTINENTAL UNITED STATES:

In the event the Company elects to repair a covered item and it is, in the judgment of the Company, impractical to return the equipment or parts for repairs, the Company may arrange for the repairs to be made by its personnel or, at its option, sublet such repairs to a qualified company. The Customer will be expected to cooperate by making the equipment or parts available and accessible when the work is scheduled and is expected to provide the necessary utilities. If local labor conditions prohibit such work being done by Company personnel under the conditions and at the rates payable by its contracts with its employees, the Company obligation shall be limited to supervision of the work, replacement of defective parts, and labor costs in an amount equal to the amount which would be payable for a reasonable number of hours required to make the repairs at the rates payable under the terms of Company contracts with its employees. In such event, all labor costs shall be paid by the Customer and the Company will reimburse the Customer to the extent set forth above.

E. REPAIR OF EQUIPMENT INSTALLED OUTSIDE THE CONTINENTAL UNITED STATES:

In the event the Company elects to repair a covered item for a Customer located outside the continental United States and it is, in the judgment of the Company, impractical to return the equipment for repairs, the Company shall have the additional options (in addition to the other options described herein) of either sending a service representative to repair (or supervise the repairs) or paying Customer a reasonable amount to allow the Customer to have the repairs made locally; provided, that in such situation, Company shall have no obligation to repair or replace equipment or parts that are repaired on by third party contractors selected by Customer.

