


LAKE PRODUCTS LTD

MANUFACTURERS AND DISTRIBUTORS

15 January 2026

Pipetite® Vacuum Pressure Test

Product Name: Pipetite® Standard

<u>Sample</u> Pipetite® Standard 0-65 Photo of test rig set up	
Test Details:	Vacuum tested at approximately -1100Pa
Guage details:	WIKA CPG1200 calibrated vacuum guage
Test completed on pressure rated box:	IP68
Test Duration time:	2 hours
Test Result: Set up and vacuum tested Pipetite® Standard 0-65 at about -1100Pa for 20 minutes. There was no pressure change for the 20 minute duration. Continued the test for 2 hours and no pressure change occurred. Observation: No detrimental effect to the physical or mechanical properties of the sample.	

Yours faithfully


Andrew Haynes
Director